



BULGARKONTROLA S.A.

CARGO & DAMAGE SURVEYS, LABORATORY ANALYSES,
CONFORMITY ASSESSMENT & TECHNICAL INSPECTIONS,
MANAGEMENT SYSTEMS, ORGANIC CERTIFICATION

Head office: 23, Sitnyakovo Blvd., 1505 Sofia, Bulgaria
Emergency mobile: +359 889 400 400, Tel.: +359 2 989 4070, Fax: +359 2 988 2354
E-mail: sales@bulgarkontrola.bg, cert@bulgarkontrola.bg

CERTIFICATE OF CONFORMITY 14 – НУРВСИРСБ – 3529

Issued pursuant to Art. 14, par. 1 and par.2 of the Regulation № РД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

SINGLE SANITARY TAP WARE MECHANICAL MIXERS

With trademark "Fiore"

Are designed for construction of water-supply pressure piping systems inside buildings with water for human consumption, with operating pressure PN 10 bar, maximum permissible temperature 90° C, with series, description and art and evaluated characteristics in accordance with national requirements as per Supplement № 1 to this Certificate.

placed on the market by
FIORE Rubinetterie S.r.l.

Via Maggiate N.68/C, 28021 Borgomanero (NO), Italy

manufactured by
FIORE Rubinetterie S.r.l.

Via Maggiate N.68/C, 28021 Borgomanero (NO), Italy

This certificate certifies that the product has been evaluated and meets national requirements set out in

BDS EN 817:2008

*and item 8.1 of Annex 3 to of Order № 02-14-1329 from 03.12.2015,
the Minister of Regional Development and Public Works,
Amendment and addition by Order № RD-02-14-590 from 05.07.2017
and Order № RD-02-14-257 from 13.03.2019*

The Certificate was issued on **17/02/2021**, cancel the Certificate № 14– НСИОСП-3344 from **24/02/2020** and remains valid for three years until **16/02/2024**, provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

Place: Sofia
Date: 17/02/2021

Director of "Conformity Assessment" Dept.

[Signature]
/T. Lyubanova/

BULGARKONTROLA S.A.– Sofia with identification number 14 of register Ministry of Regional Development and Public Works Permit № ПОСПИ-14 on 15.09. 2016 , issued by Ministry of Regional Development and Public Works



1. Series, description, and art.№

Description	Series/Art. №	Description	Series/Art. №
1. Series „KUBE”		5. Series “KEVON CHIC”	
1.1. Bath /shower mixer	100 CR8552; 100 CR8551; 100 CR8540; 100 CR8542; 100 CR7515; 100 CR7517; 100 CR7501; 100 CR7516; 100 CR 7519; 100 CR 7502; 100 CR 8556; 100CR8554; 30CR8595	5.1. Bath /shower mixer	81OX8150;81OX8152; 81OX6510; 81OX6511; 81OX7508;81OX6515; 81OX6516;81OX7507; 81OX6517; 81OX6529;
1.2. Basin mixer	100 CR8515; 100 CR8516; 100 CR8517; 100 CR8518; 100CR7597;100CR8553	5.2. Basin mixer	81OX8120;81OX8123;81MX8123; 81TX8123; 81YX8123; 81RX8123; 81GX8123; 81WX8123; 81BX8123; 81OX8126;
1.3. Bidet mixer	100 CR8535; 100 CR8536	5.3. Bidet mixer	81OX8130;
2. Series „KOKO”		6. Series “ KYRO”	
2.1. Bath /shower mixer	87 CR5550 ; 87 CR5551; 87 CR5543 ; 87 CR5540; 87 CR7565; 87 CR7506. 87 CR7561; 87 CR7515; 87 CR7517; 87 CR7501; 87 CR7513; 87 CR7511. 87 CR7502; 87 CR7563 ; 87 CR7564. 87 CR7503;	6.1. Bath /shower mixer	86CR8150; 86CR8152; 86CR8151; 86CR6511; 86CR6515;86CR6517;
2.2. Basin mixer	87 CR5515; 87 CR5516 87 CR5517; 87 CR5518; 87 CR7535 ;	6.2. Basin mixer	86CR8110; 86CR7526; 86CR8112;86CR8119;
2.3. Bidet mixer	87 CR5535; 87 CR5536	6.3. Bidet mixer	86CR3710; 86CR8135
3. Series „KERA”		6.4. Sink mixer	86CR5480; 86CR8126; 86CR5442. 86CR5447;
3.1. Bath /shower mixer		7. Series “KATANA”	
3.1. Bath /shower mixer	88 CR 5550 ; 88 CR5551; 88 CR5543. 88 CR 5540; 88 CR 5555; 88 CR 7565. 88 CR 7506; 88 CR7561; 88 CR 7515; 88 CR 7517; 88 CR 7501; 88 CR7513; 88 CR7511; 88 CR7502; 88 CR 7563; 88 CR7564; 88 CR7503; 88CR7554	7.1. Bath /shower mixer	77CR7550; 77CR7552; 77CR7551; 77CR7570; 77CR7572; 77CR7575; 77CR7588; 77CR7589; 77CR7516; 77CR7508; 77CR7515; 77CR1350; 77CR7513; 77CR7507; 77CR7517; 77CR7518; 77CR7519; 77CR7510; 77CR7511; 77CR7512; 77CR7509; 77CR7538; 77CR7549; 77CR7571 77CR7501; 77CR7565;77CR7506; 77CR7561
3.2. Basin mixer	88 CR5515; 88 CR5516; 88 CR5517 88 CR5518; 88 CR7527 ; 88CR5514	7.2. Basin mixer	77CR7520; 77CR7525; 77CR7526. 77CR7528; 77CR7527; 77CR7524; 77CR7591;77CR7545; 77CR7592; 77CR7593
3.3. Bidet mixer	88 CR5535; 88 CR5536	7.3. Bidet mixer	77CR7530;
		7.4. Sink mixer	77CR4310; 77CR4318; 77CR4395. 77CR5425; 77CR5480; 77CR5489. 77CR7540.

Place: Sofia
Date: 17/02/2021

Director of "Conformity Assessment" Dept.

E. Lyubanova
/E. Lyubanova/





Supplement № 1
to Certificate of Conformity № 14- НУРВСИРСРБ-3529

Description	Series/Art. №	Description	Series/Art. №
4. Series "KEVON"		8. Series " KALOS"	
4.1. Bath /shower mixer	81 CR8150; 81 CR8152; 81 CR1500. 81 CR1510; 81 CR6510; 81 CR6511. 81 CR6515; 81 CR6517; 81 CR6516. 81 CR6519 ;81CR8140; 81CR6512; 81CR6508; 81CR1350; 81CR6507. 81CR6518; 81CR6538; 81CR7515; 81CR7517;	8.1. Bath /shower mixer	76CR7450; 76CR7451; 76CR7470. 76CR7475; 76CR7414; 76CR7415. 76CR7416; 76CR7418; 76CR7417. 76CR7419; 76CR7438; 76 CR 7501
4.2. Basin mixer	81CR8120; 81CR8123; 81CR812370; 81CR8119; 81CR8126; 81CR8125. 81CR8127;	8.2. Basin mixer	76CR7420; 76CR7427;
4.3. Bidet mixer	81CR8130;	8.3. Bidet mixer	76CR7430;
4.4. Sink mixer	81CR4510; 81CR4530; 81CR4518. 81CR6551; 81CR6550;	8.4. Sink mixer	76CR4310; 76CR4318; 76CR4395. 76CR7440;
9. Series "KYMA"		13. Series "XS"	
9.1. Bath /shower mixer	75CR6500; 75CR6501; 75CR6502; 75CR6505; 75CR6509; 75CR6510; 75CR6512; 75CR6511; 75CR6508; 75CR6515; 75CR1350; 75CR6507; 75CR6517; 75CR6516; 75CR6518; 75CR6519; 75CR6538;;	13.1. Bath /shower mixer	71CR7750; 71CR7751; 71CR7755; 71CR7756; 71CR7760; 71CR7761; 71CR7775; 71CR7770; 71CR7714; 71CR7715; 71CR7716; 71CR7789; 71CR7717; 71CR7788; 71CR7519;
9.2. Basin mixer	75CR6520; 75CR6524; 75CR8126; 75CR4310; 75CR4318;	13.2. Basin mixer	71CR7721; 71CR7719; 71CR7718; 71CR7705; 71CR7701; 71CR7720; 71CR7725; 71CR7727; 71CR7710; 71CR7711;
9.3. Bidet mixer	75CR6530;	13.3. Bidet mixer	71CR7732; 71CR7730; 71CR7735;
9.4. Sink mixer	75CR4395; 75CR6550; 75CR6551; 75CR5425; 75CR5431; 75CR5480; 75CR5489; 75CR5490; 75CR5499;	13.4. Sink mixer	71CR7740; 71CR7742;
10. Series " KYMA SKY"		14. Series "XS-VIP"	
10.1. Bath /shower mixer	78CR6500; 78CR6502; 78CR6510; 78CR6511; 78CR6516; 78CR6515; 78CR6520; 78CR6530; 78CR4318; 78CR7301; 78CR7302; 78CR7310; 78CR7311; 78CR7316; 78CR7315; 78CR7318; 78CR7317; 78CR7319;	14.1. Bath /shower mixer	79CR7519
10.2. Basin mixer	78CR7320;	14.2. Basin mixer	79CR7755
10.3. Bidet mixer	78CR7330;	14.3. Bidet mixer	-
10.4. Sink mixer	78CR7350; 78CR7351; 78CR4318; 78CR5461; 78CR5465;	14.4. Sink mixer	79CR7742
11. Series " XO "		15. Series "XS-SKY"	
11.1. Bath /shower mixer	73CR7301; 73CR7302; 73CR7310; 73CR7311; 73CR7316; 73CR7315; 73CR7318; 73CR7317; 73CR7319;	15.1. Bath /shower mixer	85CR7750; 85CR7414
11.2. Basin mixer	73CR7320;	15.2. Basin mixer	85CR7719
11.3. Bidet mixer	73CR7330;		
11.4. Sink mixer	73CR7350; 73CR7351; 73CR4318; 73CR5461; 73CR5465;		

Place: Sofia
Date: 17/02/2021

Director of "Conformity Assessment" Dept.

/T. Lyubenova/



BULGARKONTROLA S.A.– Sofia with identification number 14 of register Ministry of Regional Development and Public Works
Permit № ПООСН-14 on 15.09. 2016, issued by Ministry of Regional Development and Public Works



Supplement № 1
to Certificate of Conformity № 14- HYPBCIICPB-3529

Description	Series/Art. №	Description	Series/Art. №
12. Series „KRUNO”		16. Series “XENON”	
15.1. Bath /shower mixer	74CR7304 ; 74CR7302 ; 74CR7310 ; 74CR7311 ; 74CR7315, 74CR7317 ; 74CR7316 ; 74CR7319, 74CR7318	16.1. Bath /shower mixer	44CR5150; 44CR5151; 44CR5155. 44CR5175; 44CR5170; 44CR5171. 44CR5146; 44CR5168; 44CR5167; 44CR5169; 44CR5189; 44CR7508; 44CR7515; 44CR7513; 44CR7507; 44CR7517; 44CR5190; 44CR5191; 44CR5192; 44CR7715; 44CR5145. 44CR7718; 44CR5158; 44CR7501 30CR8590
15.2. Basin mixer	74CR2210 ; 74CR7320	16.2. Basin mixer	44CR5227; 44CR5271; 44CR5272. 44CR5273; 44CR5262; 44CR5264. 44CR5265; 44CR5292; 44CR7728. 44CR5283; 44CR5284; 44CR5287. 44CR5288; 44CR5276; 44CR5290; 44CR5291; 44CR5142
15.3. Bidet mixer	74CR7330	16.3. Bidet mixer	44CR5371; 44CR5372; 44CR7768
		16.4. Sink mixer	44CR5461; 44CR5462; 44CR5480; 44CR5489; 44CR5490; 44CR5499; 44CR5441; 44CR5442; 44CR5443; 44CR5446; 44CR5447; 44CR5448; 44CR5455; 44CR5456; 44CR5451; 44CR5471; 44CR5472; 44CR5465; 44CR5425; 44CR5467
17. Series “XQ”		20. Series “PLANET”	
17.1. Bath /shower mixer	50CR7715; 50R7716; 50CR7718; 50CR7717	20.1. Bath /shower mixer	37CR1000; 37CR1090; 37CR1095; 37CR1455; 37CR1260; 37CR1210; 37CR1200; 37CR1250; 37CR1230; 37CR1240; 37CR1335;
17.2. Basin mixer	50CR7728	20.2. Basin mixer	37CR2210; 37CR2243; 37CR2295;
17.3. Bidet mixer	50CR7768; 50CR7738	20.3. Bidet mixer	37CR3210;
		20.4. Sink mixer	37CR4316; 37CR4110; 37CR4111;
18. Series “JAFAR”		21. Series “JAFAR-SKY”	
18.1. Bath /shower mixer	47CR5104; 47CO5104; 47RR5104; 47ZZ5104; 47OO5104; 47CR5101; 47CO5101; 47RR5101; 47ZZ5101; 47OO5101; 47CR5105; 47CO5105; 47ZZ5105; 47OO5105; 47CR5127; 47CO5127; 47RR5127; 47ZZ5127; 47OO5127; 47CR5120; 47CO5120; 47OO5120 ; 47CR5121 ; 47CO5121 47RR5121; 47ZZ5121 ; 47 OO5121 ; 47CR5130; 47CO5130; 47RR5130; 47ZZ5130; 47CR5134; 47OO5130; 47CO5134; 47RR5134; 47ZZ5134; 47OO5134; 47CR5136; 47CO5136; 47RR5136; 47ZZ5136; 47OO5136 ; 47CR5138; 47CO5138; 47RR5138; 47ZZ5138; 47OO5138	21.1. Bath /shower mixer	84CR5104; 84CO5104; 84RR5104; 84ZZ5104; 84OO5104; 84CR5101; 84CO5101; 84RR5101; 84ZZ5101; 84OO5101; 84CR5105; 84CO5105; 84RR5105; 84ZZ5105; 84OO5105; 84CR5127; 84RR5127; 84ZZ5127 84OO5127; 84 CR5120; 84CO5120; 84RR5120 ; 84ZZ5120; 84OO5120; 84CR5121; 84CO5121; 84RR5121 ; 84ZZ5121; 84OO5121; 84CR5130; 84CO5130; 84RR5130; 84ZZ5130; 84OO5130; 84CR5134; 84CO5134 ; 84RR5134; 84ZZ5134; 84OO5134; 84CR5136; 84CO5136; 84RR5136; 84ZZ5136; 84OO5136; 84CR5138; 84CO5138; 84RR5138; 84ZZ5138; 84OO5138;
18.2. Basin mixer	47CR5221; 47CO5221; 47RR5221; 47ZZ5221; 47OO5221; 47CR2245; 47CO2245; 47RR2245; 47ZZ2245; 47OO2245; 47CR5225; 47CO5225; 47RR5225; 47ZZ5225; 47OO5225;	21.2. Basin mixer	84CR5221; 84CO5221; 84RR5221; 84ZZ5221; 84OO5221; 84CR2245; 84CO2245; 84RR2245; 84ZZ2245; 84OO2245; 84CR5225; 84 CO5225; 84 ZZ5225; 84OO5225;
18.3. Bidet mixer	47CR5321; 47CO5321; 47RR5321; 47 ZZ5321; 47OO5321; 47CR5314; 47CO5314; 47RR5314; 47OO5314;	21.3. Bidet mixer	CR5321; 84CO5321; 84RR5321; 84ZZ5321; 84OO5321; 84CR5314; 84CO5314; 84RR5314; 84ZZ5314; 84OO5314;

Place: Sofia
Date: 17/02/2021

Director of "Conformity Assessment" Dept. *[Signature]*
/T. Lyubenova/



BULGARKONTROLA S.A. – Sofia with identification number 14 of register Ministry of Regional Development and Public Works
Permit № POCCII-14 on 15.09. 2016, issued by Ministry of Regional Development and Public Works




Supplement № 1
to Certificate of Conformity № 14- НУРВСИРСРБ-3529

Description	Series/Art. №	Description	Series/Art. №
19. Series "MAX"		22 Series "NEXUS"	
19.1. Bath /shower mixer	32CR1000;32CR1003; 32CR1010; 32CR1090;32CR1095; 32CR1455; 32CR1250; 32CR1230; 32CR1240; 32CR1310;32CR1300; 32CR1330; 32CR1331;32CR1335; 32CR1338	22.1. Bath /shower mixer	43CR1400; 43CR1450; 43CR1410; 43CR1455; 43CR1640; 43CR1650; 43CR1600; 43CR1610; 43CR1910; 43CR1900; 43CR1930; 43CR1931; 43CR1935; 43CR1938;
19.2. Basin mixer	32CR2210; 32CR2243; 32CR2295;	22.2. Basin mixer	43CR2510; 43CR2243;
19.3. Bidet mixer	32CR3210;	22.3. Bidet mixer	43CR3510;
19.4. Sink mixer	32CR4316; 32CR4319; 32CR4318; 32CR4310; 32CR4311; 32CR4135; 32CR4090; 32CR4070; 32CR4060; 32CR4180; 32CR4181; 32CR4125; 32CR4171; 32CR4127; 32CR4128 32CR4395; 32CR4010; 32CR4020; 32CR4310;32CR4399;32CR4360; 32CR5465; 32CR4240; 32CR4260; 32CR4200; 32CR4230; 32CR4220; 32CR4231;	22.4. Sink mixer	43CR4216; 43CR4319; 43CR4318; 43CR4135; 43CR4125; 43CR4071; 43CR4127; 43CR4182; 43CR4395; 43CR4010; 43CR4020; 43CR4310; 43CR4397; 43CR399; 43CR4360; 43CR4379; 43CR5465; 43CR5462; 43CR4240; 43CR4260; 43CR4200; 43CR4220; 43CR4250; 43CR4251
23. Series "ALTURA"		25. Series "MISTRAL"	
23.1. Bath /shower mixer	41CR1500; 41CR1502; 41CR1510; 41CR1501; 41CR1511; 41CR1750; 41CR1700; 41CR1710; 41CR1760; 41CR1720; 41CR1730; 41CR1761; 41CR1721; 41CR1731; 41CR1810; 41CR1800;	25.1. Bath /shower mixer	42CR1500; 42CR1508; 42CR1510; 42CR1501; 42CR1511; 42CR1750; 42CR1700; 42CR1710; 42CR1761; 42CR1721; 42CR1731; 42CR1760; 42CR1720;
23.2. Basin mixer	41CR2710; 41CR2709; 41CR4633; 41CR2810	25.2. Basin mixer	42CR2710; 42CR2709; 42CR4633;42CR8119
23.3. Bidet mixer	41CR3710;	25.3. Bidet mixer	42CR3710;
23.4. Sink mixer	41CR4631; 41CR4510; 41CR4511; 41CR4509; 41CR4660; 41CR4659; 41CR4664; 41CR4610; 41CR4609; 41CR4730; 41CR4700; 41CR4742; 41CR4743; 41CR4715; 41CR4740; 41CR4741; 41CR4750; 41CR4751;	25.4. Sink mixer	42CR4510; 42CR4511; 42CR4509;
24. Series "KING"		26. Series "IMPERIALE"	
24.1. Bath /shower mixer	39CR1000;39CR1002; 39CR1005; 39CR1010;39CR1090; 39CR1095; 39CR1008; 39CR1455; 39CR1260; 39CR1200; 39CR1210; 39CR1250; 39CR1230; 39CR1240; 39CR1310; 39CR1300; 39CR1301; 39CR1330; 39CR1331; 39CR1335; 39CR1338;	26.1. Bath /shower mixer	83CR5104;83CO5104;83RR5104; 83ZZ5104;83OO5104;83CR5101; 83CO5101;83RR5101;83ZZ5101; 83OO5101;83CR5105;83O5105; 83RR5105;83ZZ5105;83OO5105; 83CR5127;83CO5127;83RR5127; 83ZZ5127;83OO5127;83CR5120; 83CO5120;83RR5120;83ZZ5120 ; 83OO5120;83CR5121; 83CO5121; 83RR5121 ;83RR5121 ;83ZZ5121; 83OO5121;83CR5130;83CO5130; 83ZZ5130;83OO5130;83CR513; 83CO5134;83RR5134;83ZZ5134; 83OO5134;83CR5136;83CO5136; 83RR5136;83ZZ5136;83CR5138; 83CO5138;83RR5138;83OO5138; 83ZZ5138; 83OO5138;89CR5221;

Place: Sofia
Date: 17/02/2021

Director of "Conformity Assessment" Dept.

/T. Lyubanova/



BULGARKONTROLA S.A.– Sofia with identification number 14 of register Ministry of Regional Development and Public Works
Permit № ПООСН-14 on 15.09. 2016, issued by Ministry of Regional Development and Public Works




Supplement № 1
to Certificate of Conformity № 14- НУРВСИРСРБ-3529

Description	Series/Art. №	Description	Series/Art. №
24.2. Basin mixer	39CR2210; 39CR2243; 39CR2295; 39CR2400;	26.2. Basin mixer	83CR5221; 83RR5221; 83OO5221; 83CR2245; 83CO2245; 83RR2245; 83ZZ2245; 83OO2245; 83CR5225; 83CO5225; 83RR5225; 83ZZ5225; 83OO5225;
24.3. Bidet mixer	39CR3210; 39CR3291;	26.3. Bidet mixer	83CR5321; 83CO5321; 83RR5321; 83ZZ5321; 83OO5321; 83CR5314; 83CO5314; 83RR5314; 83ZZ5314; 83OO5314;
24.4. Sink mixer	39CR4316; 39CR4319; 39CR4318; 39CR4110; 39CR4111; 39CR4135; 39CR4090; 39CR4070; 39CR4060; 39CR4160; 39CR4180; 39CR4181; 39CR4125; 39CR4071; 39CR4127; 39CR4128; 39CR4182; 39CR4183; 39CR4184; 39CR4395; 39CR4010; 39CR4020; 39CR4310; 39CR4397; 39CR4399; 39CR4360; 39CR4379; 39CR4380; 39CR5465; 39CR4240; 39CR4260; 39CR4250; 39CR4251; 39CR4252; 39CR4296; 39CR4200; 39CR4230; 39CR4220; 39CR4231		
27. Series "IMPERIALE-BLACK"		28. Series "CLASS"	
27.1. Bath /shower mixer	89CR5104; 89CO5104; 89RR5104; 89ZZ5104; 89OO5104; 89CR5101; 89CO5101; 89RR5101; 89ZZ5101; 89 OO5101; 89 CR5105; 89 CO5105; 89RR5105; 89ZZ5105; 89OO5105; 89CR5127; 89CO5127; 89RR5127; 89ZZ5127; 89OO5127; 89CR5120; 89CO5120 ; 89RR5120; 89ZZ5120; 89OO5120; 89CR5121; 89CO5121; 89RR5121; 89ZZ5121; 89OO5121; 89CR5130; 89CO5130; 89RR5130; 89ZZ5130; 89OO5130; 89CR5134; 89CO5134; 89RR5134 ; 89ZZ5134 ; 89OO5134; 89CR5136; 89CO5136; 89RR5136; 89ZZ5136; 89OO5136; 89CR5138; 89CO5138; 89OO5138; 89RR5138; 89ZZ5138; 89OO5138;	28.1. Bath /shower mixer	38CR1000; 38CO1000; 38CR1010; 38CO1010; 38CR1260; 38CO1260; 38CR1200 ; 38CO1200; 38CR1210; 38CO1210; 38CR1300; 38CO1300; 38CR1331; 38CO1331
27.2. Basin mixer	89CR5221; 89CO5221; 89RR5221; 89 ZZ5221; 89 OO5221; 89 CR2245; 89 CO2245; 89 RR2245; 89 RR2245; 89 ZZ2245; 89 OO2245; 89 CR5225; 89 CO5225; 89 RR5225; 89 ZZ5225; 89 OO5225;	28.2. Basin mixer	38CR2210; 38CO2210;
27.3. Bidet mixer	89 CR5321; 89 CO5321; 89 RR5321; 89 ZZ5321; 89 OO5321; 89 CR5314; 89 CO5314; 89 RR5314; 89 ZZ5314; 89 OO5314;	28.3. Bidet mixer	38CR3210; 38CO3210;
29. Series "CLIN"			
29.1. Basin mixer	33CR2210; 33CR2710;		
29.2. Sink mixer	33CR4110 ; 33CR4510 ; 33CR4200 ; 33CR4220		
30. Series "S122"			
30.1 Bath mixer	122 CR V608	30.2 Basin mixer	122 CR L608
30.3 Sink mixer	122 CR C608		
31. Series "S123"			
31.1 Bath mixer	123 CR V603	31.2 Basin mixer	123 CR L603
31.3 Sink mixer	123 CR C603		

Place: Sofia
Date: 17/02/2021

Director of "Conformity Assessment" Dept.
(Signature)
/T. Lyubenova/



BULGARKONTROLA S.A. – Sofia with identification number 14 of register Ministry of Regional Development and Public Works
Permit № ПООСН-14 on 15.09. 2016, issued by Ministry of Regional Development and Public Works



2. Evaluated characteristics in accordance with national requirements

Characteristics	Requirement to declare / border level
Leaktightness <ul style="list-style-type: none">- leaktightness of the thermostatic mixing valve and of the obturator under hydrostatic pressure upstream of the obturator with the obturator in the closed position- leaktightness of the obturator of the thermostatic mixing valve under hydrostatic pressure crossflow with the obturator closed- leaktightness of the thermostatic mixing valve under hydrostatic pressure downstream of the obturator with the obturator open	No leakage during the test, according BDS EN 817, item 8, tabl. 8
Mechanical pressure resistance	No permanent deformation in any part of the thermostatic mixing valve, according BDS EN 817, item 9, tabl. 9
Hydraulic characteristics (flow rate)	4±12 l/ min according BDS EN 817, item 10.3, tabl. 10

Place: Sofia
Date: 17/02/2021

Director of "Conformity Assessment" Dept.



/T. Lyubanova/